



Ref.: DA/2-4/2014/T23/14-6

Date: December 14, 2014

Circular No. (3)

Reference: SEZAD Tender No. (23-2014) "Construction of Main Road Improvements at Duqm Centre"

Collection of Tender Documents: 03/11/2014.

Submission Date: 16/12/2014.

Subject: Replies to Bidders' Queries

Dear Bidders,

Please find below replies to queries received from Bidders:

Query No.	QUERY	REPLY
1	Tender Document, volume III/IV – Bill of Quantities, Bill No. (VI) – Incidental Construction, Page VI- IV, Item No. 14.1.7 (vii) Overhead sign support including foundation (Cantilever) Please provide drawing detail for Overhead sign support (Cantilever) to price the above item.	Drawing No. SA - 275 / 102 / TD / 1J003 A "Typical Details for Cantilever Structure" and Drawing No. SA – 275 / 102 / TD / 1J003 B "Typical CIDH Foundation Details" is being issued through Addendum No. 3.
2	Tender Document, Volume III/IV - Bill of quantities, Bill No. (VII) – Road lighting and electric installations, Page No. VII-VI, item No. 15.18.3, Design, Supply, Installation, commissioning and testing of the traffic light control system including but not limited to Grid smart cameras, hardware and software, civil works etc. for loop detection,	Pedestrian push buttons and vehicle detection camera shall be required. Regarding push buttons please refer Preamble to BOQ, Volume III / IV of Tender Documents. The detail given in Standard Specifica-



<p>incident detection, stop bar detection, traffic counts including turn movements count and vehicle classification.</p> <p>Tender Document, Volume IV/IV – Drawings, Drawing No. SA-275/102/TD/1C013 to 1C016</p> <p>The above drawings indicate pedestrian bush buttons to be installed which is not part of BOQ. On the other hand the above BOQ item states Vehicle detection camera which is not mentioned in the drawing.</p> <p>Please clarify and specify the correct requirements</p>	<p>tions Volume 3, Clause 20.1.3.e.xxii. states that “Cost of work items for which there are no direct payments and which are considered in the Specification and other contract documents as subsidiary to other items in the Bill of Quantities”.</p> <p>Regarding detection camera please refer description of Item 15.11, Traffic Signals, on page VII-IV of BOQ, Volume III/IV of Tender Documents.</p>
--	--

NOTES:

1. Any queries and/or clarifications are to be officially submitted to SEZAD Tenders email: sezadtenders@duqm.com
2. All Bidders are to endorse this circular and attach it as part of their tender submission.
3. Bidders are advised that ‘Query to this tender’ is **CLOSED**. (Tender Submission Date: 16th Dec 2014).

Yours Sincerely,

SEZAD Tenders and Contracts Department

